



## County of Fresno

Department of Public Health

Edward L. Moreno, M.D., M.P.H., Director-Health Officer

January 14, 2009

California Energy Commission  
Joseph Douglas, Project Manager  
1516 9<sup>th</sup> Street, MS-15  
Sacramento, CA 95814

**DOCKET**

**08-AFC-12**

DATE JAN 22 2009

RECD. JAN 22 2009

999999999  
LU0015111  
PE 2600

Dear Mr. Douglas:

**SUBJECT:** San Joaquin Solar 1 & 2 Power Project, 08-AFC-12

**LOCATION:** Jayne Avenue, Coalinga, APN # 085-030-55s, 57s, & 58s.

The Fresno County Department of Public Health, Environmental Health Division has reviewed the documents circulated for subject project and concurs with the information contained within. The following items are re-iterated in regards to this Departments regulatory oversight over the project:

- Prior to occupancy, the applicant shall complete and submit either a Hazardous Materials Business Plan to the Fresno County Department of Public Health, Environmental Health Division. Contact the Certified Unified Program Agency at (559) 445-3271 for more information.
- All hazardous waste shall be handled in accordance with requirements set forth in the California Health and Safety Code, Chapter 6.5. This chapter discusses proper labeling, storage and handling of hazardous wastes.
- The project description and site plan indicate the use of ammonia. Based on the information contained in the operational statement, this facility will have to comply with the California Accidental Release Prevention (Cal-ARP) Program (Title 19, California Code of Regulations, Section 2745.1(e)).

An RMP shall be submitted to the local Certified Unified Program Agency (CUPA) prior to the date in which the regulated substance (ammonia) is first present in the process above the listed threshold quantity (500 pounds). Contact the local CUPA at (559) 445-3271 for more information.

- Should a water well be drilled, the water well contractor selected by the applicant will be required to apply for and obtain a Permit to Construct a Water Well from the Fresno County Public Health Department, Environmental Health Division. Any new well drilled shall meet industrial well construction standards. Contact the Water Surveillance Program at (559) 445-3357 for more information.

Joseph Douglas  
San Joaquin Solar 1 & 2 Power Project  
January 14, 2009  
Page 2 of 2

If I can be of further assistance, please contact me at (559) 445-3357.

Sincerely,

R.E.H.S., M.S.  
Environmental Health Specialist  
Environmental Health Division

ga

cc: Vince Mendes, Environmental Health Division (CT 7800)

CEC 08-AFC-12 San Joaquin Solar Comments